

**Reltronix Ltd**

Trafalgar House
Tharston Industrial Estate
Norwich, Norfolk NR15 2PD

www.reltronix.com

sales@reltronix.com

Tel: +44(0)1603 859640

MIL PRF 38534 CLASS H TRAVELLER

Customer:SiS	Cust PO#:INTERNAL	Cust Spec:Man Data Sheet
LQH #:057	Bonding Diagram#: DBD072	SO:INTERNAL
Device:7805AC	Device IIL:11198	Diff Lot: PD17762A-1 W-1
Bond Wire:Au	Package Style: 16 Pin DIL	Package IIL:6316
Die Attach Type:Ag	Lid Style: 16 Pin Combo Lid	Lid IIL:8053

SEQ	OPERATION/PS	CONDITIONS	QTY	ACCEPT	REJ.	DATE	SIG.	COMMENTS
1	100% Die Visual QS011	MIL STD 883 TM 2010	15	15		31/07/25	SG	Equipment #:1
2	Die Attach PS0018	Cure Epoxy 1Hr @150°C Oven Temp Check:152°C	15	15		31/07/25	DPB	Equipment #:6
3	Wire Bond PS0020	Wire Type: Au Diameter: 1 Mils	15	15		1/08/25	DPB	Equipment #:7
4	Internal Visual QS0029	MIL STD 883 TM 2010	15	15		1/08/25	SE	Equipment #:1
5	Lid Seal PS 00010	Cure Epoxy 1Hr @150°C	15	15		4/08/25	SR	Equipment #:8 Oven Temp Check:152°C
6	100% Electrical Test +25°C	Manufacturers Datasheet	10	10		4/08/25	DPB	Equipment #:12 Program: 7805AC.tsf
7	100% Electrical Test -55°C	Manufacturers Datasheet	10	10		4/08/25	DPB	Equipment #:12 Program: 7805AC.tsf

ALL ELECTRICAL TEST RESULTS ARE SUPPLIED ELECTRONICALLY

**Reltronix Ltd**

Trafalgar House
Tharston Industrial Estate
Norwich, Norfolk NR15 2PD

www.reltronix.com

sales@reltronix.com

Tel: +44(0)1603 859640

SEQ	OPERATION/PS	CONDITIONS	QTY	ACCEPT	REJ.	DATE	SIG.	COMMENTS
8	100% Electrical Test +125°C	Manufacturers Datasheet	10	10		4/08/25	DPB	Equipment #:12 Program: 7805AC.tsf
9	Bond Pull Test Bake PS0005	MIL STD 883 TM2011 1hr 300°C bake	10	10		5/08/25	DPB	Equipment #:8 Oven Temp Check# 301°C
10	Bond Pull Test PS0006	MIL STD 883 TM2011 Attach Electronic Results to Folder	10	10		5/08/25	DPB	Equipment #:15 BPR:0065
11	Final QA QS0032	Check Test Records and Documentation	10	10		6/08/25	DSB	
12	Dispatch goods and Electronic Records to customer		1	1		6/08/25	RB	

ALL ELECTRICAL TEST RESULTS ARE SUPPLIED ELECTRONICALLY

Data

Device #	Result	1 Vo 10V/500mA	2 Vo 7V/5mA	3 Vo 7V/1A	4 Vo 20V/5mA	5 Vo 20V/1A	6 RegLine 1	7 RegLine 2	8 RegLoad 1	9 RegLoad 2	10 Iq	11 SVR	12 DOV	13 Isc
Unit		V	V	V	V	V	mV	mV	mV	mV	mA	dB	V	mA
Lower limit		4.800	4.750	4.750	4.750	4.750	-100.000	-50.000	-100.000	-50.000	0.000	62.000	0.500	0.00
Upper limit		5.200	5.250	5.250	5.250	5.250	100.000	50.000	100.000	50.000	8.000		2.500	1500
1	Pass	4.92	4.96	4.84	4.96	4.88	2.53	-0.98	-67.85	-21.46	5.48	68.32	2.14	1219.80
2	Pass	5.17	5.17	4.77	5.17	5.12	3.93	2.88	-61.23	-20.63	5.44	91.92	2.25	1232.00
3	Pass	5.02	5.04	4.80	5.04	5.00	7.18	0.58	-56.61	-18.23	5.69	69.24	2.19	1286.10
4	Pass	5.01	5.03	4.81	5.03	4.98	6.24	1.15	-64.92	-25.59	5.62	70.30	2.19	1234.70
5	Pass	4.95	4.97	4.78	4.97	4.93	3.46	1.26	-57.03	-19.02	5.47	65.56	2.22	1219.20
6	Pass	4.95	4.97	4.77	4.97	4.93	4.73	-2.48	-62.19	-18.73	5.49	67.49	2.23	1215.60
7	Pass	5.01	5.02	4.80	5.02	4.99	6.62	0.73	-57.62	-17.42	5.64	69.27	2.20	1283.70
8	Pass	4.99	5.01	4.79	5.01	4.97	6.45	0.83	-58.62	-18.08	5.64	71.45	2.21	1314.00
9	Pass	5.02	5.04	4.80	5.04	5.01	7.23	-0.51	-55.88	-18.25	5.66	68.99	2.19	1238.50
10	Pass	5.01	5.02	4.77	5.02	4.99	6.87	1.01	-54.93	-17.96	5.71	70.27	2.23	1295.40

Cust Spec :MAN. Data Sheet

LQH #:057 7805AC TEMP =25°C



Data

Device #	Result	1 Vo 10V/500mA	2 Vo 7V/5mA	3 Vo 7V/1A	4 Vo 20V/5mA	5 Vo 20V/1A	6 RegLine 1	7 RegLine 2	8 RegLoad 1	9 RegLoad 2	10 Iq	11 SVR	12 DOV	13 Isc
Unit		V	V	V	V	V	mV	mV	mV	mV	mA	dB	V	mA
Lower limit		4.800	4.750	4.750	4.750	4.750	-100.000	-50.000	-100.000	-50.000	0.000	62.000	0.500	0.00
Upper limit		5.200	5.250	5.250	5.250	5.250	100.000	50.000	100.000	50.000	8.000		2.500	1500.00
1	Pass	4.96	4.98	4.750	4.98	4.94	6.08	0.68	-53.62	-17.95	5.47	68.53	2.25	1254.10
2	Pass	4.97	4.98	4.754	4.98	4.95	9.47	0.83	-56.38	-17.71	5.42	68.60	2.27	1280.90
3	Pass	4.96	4.98	4.759	4.98	4.95	3.58	1.75	-47.46	-17.51	5.43	66.76	2.24	1254.60
4	Pass	5.14	5.15	4.764	5.15	5.13	9.57	-2.59	-45.29	-17.39	5.43	68.65	2.25	1259.10
5	Pass	4.94	4.98	4.813	4.98	4.91	4.20	-2.48	-47.87	-15.87	5.43	68.70	2.18	1269.50
6	Pass	5.03	5.04	4.770	5.04	5.01	10.68	0.44	-46.47	-15.21	5.61	70.22	2.25	1344.80
7	Pass	5.02	5.04	4.796	5.04	5.01	7.76	0.90	-52.29	-16.64	5.57	71.58	2.21	1276.00
8	Pass	5.01	5.03	4.776	5.03	4.99	6.14	0.44	-50.18	-16.13	5.73	70.76	2.22	1300.60
9	Pass	5.02	5.03	4.755	5.03	5.00	10.84	2.64	-47.31	-15.88	5.65	71.46	2.25	1360.00
10	Pass	5.00	5.02	4.761	5.01	4.99	8.63	-0.31	-46.59	-15.33	5.55	72.56	2.24	1384.90

Cust Spec :MAN. Data Sheet

LQH #:057 7805AC TEMP =-55°C



Data

Device #	Result	1 Vo 10V/500mA	2 Vo 7V/5mA	3 Vo 7V/1A	4 Vo 20V/5mA	5 Vo 20V/1A	6 RegLine 1	7 RegLine 2	8 RegLoad 1	9 RegLoad 2	10 Iq	11 SVR	12 DOV	13 Isc
Unit		V	V	V	V	V	mV	mV	mV	mV	mA	dB	V	mA
Lower limit		4.800	4.750	4.750	4.750	4.750	-100.000	-50.000	-100.000	-50.000	0.000	62.000	0.500	0.00
Upper limit		5.200	5.250	5.250	5.250	5.250	100.000	50.000	100.000	50.000	8.000		2.500	1500.00
1	Pass	5.01	5.03	4.87	5.03	4.98	-9.84	-2.95	-64.53	-21.49	5.70	72.06	2.14	1084.70
2	Pass	5.02	5.04	4.81	5.04	5.00	5.52	0.79	-54.25	-17.49	5.67	67.45	2.19	1114.90
3	Pass	5.00	5.02	4.83	5.02	4.98	2.91	0.88	-55.40	-17.56	5.65	70.52	2.17	1116.30
4	Pass	4.98	5.00	4.83	5.00	4.96	2.39	3.10	-57.92	-16.51	5.66	72.95	2.17	1145.20
5	Pass	4.91	4.95	4.86	4.95	4.87	0.23	3.25	-64.64	-19.58	5.49	68.04	2.11	1175.20
6	Pass	5.01	5.03	4.85	5.03	4.99	5.25	0.96	-57.26	-19.78	5.62	70.66	2.14	1185.30
7	Pass	5.01	5.03	4.85	5.03	4.99	3.35	2.13	-59.78	-21.66	5.62	71.29	2.13	1183.20
8	Pass	5.14	5.14	4.81	5.15	5.11	7.56	-2.30	-60.40	-19.16	5.44	72.73	2.22	1160.50
9	Pass	4.93	4.95	4.82	4.95	4.91	-1.18	1.71	-62.79	-17.59	5.47	64.38	2.17	1133.30
10	Pass	4.93	4.95	4.80	4.95	4.91	0.74	1.23	-65.00	-19.53	5.51	69.39	2.18	1141.60

Cust Spec :MAN. Data Sheet

LQH #:057 7805AC TEMP =125°C



Part #	7805AC	Date	5th August 2025
Sample Qty	5	Bond Type	Ball
Wire Size	25μ	Wire Type	Au
Min allowable strength	2.5gm	BPR	0077
Customer	XXXXX	Customer PO- SO	Internal
Batch #	LQH0057	Equipment	XYZTEC

SN: 11			SN: 12			SN: 13			SN:14			SN:15					
#	F	C	#	F	C	#	F	C	#	F	C	#	F	C	#	F	C
1	6.35	8	3	7.20	8	5	6.35	8	7	7.02	8	9	7.77	8			
2	6.61	8	4	6.72	8	6	6.11	8	8	7.83	8	10	5.71	8			

F=Pull Strength in gms C=Failure Code

CODES

1. No Wire Break
2. Bond lift from Die
3. Bond lift from Post
4. Wire breaks at Heal
5. Die Metallisation delaminates
6. No Connection
7. Wire Breaks from Die
8. Bond Breaks at span